

395203

30-2E-19K



WATER WELL REPORT

Original & 1st copy - Ecology, 2nd copy - owner, 3rd copy - drillerDEPARTMENT OF
ECOLOG
State of Washington

Construction/Decommission ("x" in circle)

☒ Construction☐ Decommission ORIGINAL INSTALLATION

Notice of Intent Number

PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal
☐ DeWater ☐ Irrigation ☐ Test Well ☐ Other

TYPE OF WORK: Owner's number of well (if more than one) 8
☒ New well ☐ Reconditioned Method: ☐ Dug ☐ Bored ☐ Driven
☐ Deepened ☒ Cable ☐ Rotary ☐ Jetted

DIMENSIONS: Diameter of well 8 inches, drilled 107 ft.
 Depth of completed well 107 ft.

CONSTRUCTION DETAILS
 Casing ☒ Diam. 8 from +1.5 ft. to 97 ft.
 Installed: ☐ Liner installed " Diam. from " ft. to " ft.
☐ Threaded " Diam. From " ft. to " ft.

Perforations: ☐ Yes ☒ No
 Type of perforator used _____
 SIZE of perfs _____ in. by _____ in. and no. of perfs _____ from _____ ft. to _____ ft.
 Screens: ☒ Yes ☐ No x ☐ K-Pac Location _____
 Manufacturer's Name _____
 Type STAINLESS Model No. TELE _____
 Diam. 8 Slot size 12 from 97 ft. to 107 ft.
 Diam. Slot size from ft. to ft.

Gravel/Filter packed: ☐ Yes ☒ No Size of gravel/sand _____
 Materials placed from _____ ft. to _____ ft.

Surface Seal: ☒ Yes ☐ No To what depth? 18 ft.
 Material used in seal BENTONITE 3/8 CHIPS
 Did any strata contain unusable water? ☐ Yes ☒ No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

PUMP: Manufacturer's Name _____
 Type: _____ H.P. _____

WATER LEVELS: Land-surface elevation above/ mean sea level 166 ft.
 Static level 85.4 ft. below top of well Date 11/1/2010
 Artesian pressure _____ lbs. per square inch Date _____
 Artesian water is controlled by _____ (cap, valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? ☐ Yes ☒ No If yes, by whom? _____
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

 Date of test _____
 Bailer test 15 gal./min. with 4 ft. drawdown after 3 hrs.
 Airstest _____ gal./min. with stem set at _____ ft. for _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? ☐ Yes ☒ No

CURRENT

Notice of Intent No. _____

W 267943

Unique Ecology Well ID Tag No _____

BBF 269

Water Right Permit No. _____

Property Owner Name Lagoon Point Water District

Well Street Address Smugglers Cove Rd

City Greenbank County Island

Location NW 1/4 1/4 of the SE 1/4 Sec19 Twn30 R 2 EWM ☒
(s, t, r Still REQUIRED) Or WWM ☐

Lat/Long

Lat Deg _____ Lat Min/Sec _____

Long Deg _____ Long Min/Sec _____

Tax Parcel R 23019-275-2740

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. (USE ADDITIONAL SHEETS IF NECESSARY.)

Material	FROM	TO
BROWN SAND	0	3
SILTY SAND	3	8
HARDPAN	8	52
COMPACT SAND&GRAVEL	52	94
WATER SAND CLEAN	94	101
WATER SAND SILTY	101	107
CLAY	107	

WELL SITE MEETS ALL SET BECKS
REQUIREMENTS UNDER ICC 8.09
BASED ON INFORMATION FROM OWNERRECEIVED
DEPARTMENT OF ECOLOGYWATER RESOURCES PROGRAM
NWRO

Start Date 10/25/2010 Completed Date 11/1/10

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee Name (Print) Gerlof Boonstra

Driller/Engineer/Trainee Signature _____

Driller or trainee License No. 0038

IF TRAINEE: Driller's License No. _____

Driller's Signature: _____

Drilling Company WHIDBEY WELL DRILLERS

Address 716 Holbrook Rd

City, State, Zip Coupeville, WA, 98239

Contractor's

Registration No. WHIDBWD917DS

Date 11/1/2010